## **AQUAFIDES**

## **UVC DESINFECTION SYSTEM**

"PSS400" 1 AF300 T

TECHNICAL DATE SHE	EET pag	ge 1/2	UVC single-lamp system - COMPACT T
SYSTEM TYPE       Product       Manufacturer			AQUAFIDES AQUAFIDES
Flow rate calculated Head loss flow-max certified (without geod Fluenz - calculated PSS (Point-Source-Sur Tr100 @ 254nm Tr50 @ 254nm Tr10 @ 254nm	• /	m <sup>3</sup> /h bar J/m <sup>2</sup> % %	1,15 - 38,51 0,136 400 1 - 100 10 - 100 63,1 - 100
SSK @ 254nm Temperature of process water*	from - up to from - up to	m-1 ℃	20 - 0 0 - 65
CONTROL - CABINET			DigiSys Compact 300 - 400
System design Control mode Control data and software update access			Bus-RS485 digital USB
Software service and settings via laptop         Control display multi 3-colours (green, yellow and red)       lines         Control button for the operation of the system       button         Product (control-cabinet)			yes 4 5 Rolec
Material (control-cabinet) Colour (control-cabinet) Dimensions	grey width	RAL mm	aluminium 7040 330
Weight Operating voltage (nominal voltage)	height depth	mm mm kg V / Hz	200 120 5,2 230 / 50
Operating connection         0           Total consumed power (normal operation)         W		0 W cos φ	1L / N / PE 270 0,99 1,2
Protection class     IP       Feed line fuse (data for cutout type D)     pc x A       UVC lamp cable length (control-cabinet/reactor)     m       Power line cable length (control-cabinet/power plug)     m		IP pc x A m	65 1 x 13 4 2,5
Environmental temperature control-cabinet     °C       EVG ELECTRONIC BALLAST			5 - 35 1 AF300 T
Туре			Compact 300 - 400
Design Number of EVG´s UVC lamps per EVG System design		EVG pcs pcs	combined with controll mode 1 1 Bus-RS485
Control mode UVC power line regulation Overall efficiency (normal operation EVG a	ind UVC lamp)	% %	digital 50 - 120 ≥ 90

## AQUAFIDES

## UVC DESINFECTION SYSTEM

"PSS400" 1 AF300 T

TECHNICAL DATE SH	EET page 2/2	UVC single-lamp system - COMPACT T
IRRADIATION CHAMBER (IC)		1 AF300 T
Irradiation chamber connection	mm	DN 65
Connecting dimensions acc. Norm (flang		DIN 2642
Design - lay-out inlet to outlet flange	· · ·	Z - design
Irradiation chamber	horizontal	yes
possible fitting positions	vertical	yes
	reverse (UVC lamp)	yes
Material water-swept parts		stainless steel
Material number		1.4404
Material water-swept seals Dimensions	O-rings	EPDM
	width mm	366
	height (length) mm	1.163
	depth mm	185
	EDØ mm	172
Height (length) IC including disassemblin		2.355
Quartz tubes flanged with adapter	EDØ mm	38
Number of quests to bes	length mm	1.157
Number of quartz tubes	pcs	1
Weight without medium	approx. kg	20,5
Weight with medium	approx. kg	43,9
Irradiation chamber volume	approx.	23,4
Drain / vent (stainless steel ball valves)	IP	G 1/4"
Irradiation chamber protection class		<u> </u>
Operating pressure (maximal)	bar	10
UVC LAMP		1 AF300 T
Туре		AF300A
Product / Manufacturer		AQUAFIDES
Number of UVC lamps	pcs	1
UVC lamp kind		amalgam
UVC lamp power (Watt UVC per lamp - r		78,6
UVC lamp power (Watt UVC after 8.760		55,0
UVC lamp power @ 253,7 nm	%	≥ 85
UVC lamp wavelength @ ≤ 240 nm		filtrated
Power consumption per UVC lamp (inclu		270
UVC lamp currentconsumption per UVC		3,4
UVC lamp connection	special	4-pin
Lamp service life **	hours	12.000
		1 AF300 T
Туре	DC	1 AF300 T DigiNorm
Type Numbers of UVC sensors	pc	DigiNorm 1
Type Numbers of UVC sensors Design according ÖNORM M5873-1D		DigiNorm 1 yes
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1	D	DigiNorm 1 yes yes
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873-	D 1D	DigiNorm 1 yes yes yes yes
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873-1 Calibration according ÖNORM M 5873-11	D ID	DigiNorm 1 yes yes
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period	D 1D	DigiNorm 1 yes yes yes yes yes 1
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period System design UVC sensor	D ID	DigiNorm 1 yes yes yes yes 1 Bus-RS485
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period System design UVC sensor Control mode	D 1D D year	DigiNorm 1 yes yes yes yes 1 Bus-RS485 digital
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period System design UVC sensor Control mode UV measurement range	D 1D D year W/m <sup>2</sup>	DigiNorm           1           yes           yes           yes           yes           ges           yes           ges           ges           ges           ges           ges           digital           2 - 500
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period System design UVC sensor Control mode UV measurement range Output signal (switchable)	D 1D D year W/m <sup>2</sup> mA	DigiNorm           1           yes           yes           yes           yes           1           Bus-RS485           digital           2 - 500           0/4 - 20
Type Numbers of UVC sensors Design according ÖNORM M5873-1D Type tested according ÖNORM M5873-1 Recalibration according ÖNORM M5873- Calibration according ÖNORM M 5873-11 Recalibration time period System design UVC sensor Control mode UV measurement range Output signal (switchable) Exactness of the measurements	D 1D D year W/m <sup>2</sup> MA %	DigiNorm           1           yes           yes           yes           yes           1           Bus-RS485           digital           2 - 500           0/4 - 20           ± 2
Type         Numbers of UVC sensors         Design according ÖNORM M5873-1D         Type tested according ÖNORM M5873-1         Recalibration according ÖNORM M5873-1         Recalibration according ÖNORM M5873-1         Recalibration according ÖNORM M5873-1         Recalibration time period         System design UVC sensor         Control mode         UV measurement range         Output signal (switchable)         Exactness of the measurements         Sensitive @ 254 nm         Temperature stability	D 1D D year W/m <sup>2</sup> mA	DigiNorm           1           yes           yes           yes           yes           1           Bus-RS485           digital           2 - 500           0/4 - 20

\* Medium temperature: in connection with the disinfection performance – please absolutely taking into account at dimensioning the plants

\*\* Lamp quarantee and usage agreements are mentioned in the general Terms and Conditions of UVC lamps